



**DEPARTMENT OF LABOR & ECONOMIC GROWTH
DIRECTOR'S OFFICE
OCCUPATIONAL HEALTH STANDARDS**

Filed with the Secretary of State on January 1, 1975

This rule takes effect 15 days after filing with the Secretary of State

Visit our website at: www.michigan.gov/mioshastandards

PART 620. VENTILATION CONTROL FOR CONSTRUCTION

Rule 6301 Ventilation Control.

(1) General.

Whenever hazardous substances such as dusts, fumes, mists, vapors, or gases exist or are produced in the course of construction work, their concentrations shall not exceed the limits specified in Rule 6201. When ventilation is used as an engineering control method, the system shall be installed and operated according to the requirements of this rule. [1926.57(a)]

(2) Local exhaust ventilation.

Local exhaust ventilation when used as described in (1) shall be designed to prevent dispersion into the air of dusts, fumes, mists, vapors, and gases in concentrations causing harmful exposure. Such exhaust systems shall be so designed that dusts, fumes, mists, vapors, or gases are not drawn through the work area of employees. [1926-57(b)]

(3) Design and operation.

Exhaust fans, jets, ducts, hoods, separators, and all necessary appurtenances, including refuse receptacles, shall be so designed, constructed, maintained and operated as to ensure the required protection by maintaining a volume and velocity of exhaust air sufficient to gather dusts, fumes, vapors, or gases from said equipment or process, and to convey them to suitable points of safe disposal, thereby preventing their dispersion in harmful quantities into the atmosphere where employees work. [1926.57(c)]

(4) Duration of operations.

(a) The exhaust system shall be in operation continually

during all operations which it is designed to serve. If the employee remains in the contaminated zone, the system shall continue to operate after the cessation of said operations, the length of time to depend upon the individual circumstances and effectiveness of the general ventilation system. [1926.57(d)(1)]

(b) Since dust capable of causing disability is, according to the best medical opinion, of microscopic size, tending to remain for hours in suspension in still air, it is essential that the exhaust system be continued in operation for a time after the work process or equipment served by the same shall have ceased, in order to ensure the removal of the harmful elements to the required extent. For the same reason, employees wearing respiratory equipment should not remove same immediately until the atmosphere seems clear. [1926.57(d)(2)]

(5) Disposal of exhaust materials.

The air outlet from every dust separator, and the dusts, fumes, mists, vapors, or gases collected by an exhaust or ventilating system shall discharge to the outside atmosphere. Collecting systems which return air to work area may be used if concentrations which accumulate in the work area air do not result in harmful exposure to employees. Dust and refuse discharged from an exhaust system shall be disposed of in such a manner that it will not result in harmful exposure to employees. [1926.57 (e)]